



Government Of West Bengal  
Office Of The Divisional Fire Officer, North 24 Parganas  
West Bengal Fire & Emergency Services  
Ghoshpara Road, P.O.- Bengal Enamel, Pin :- 743122

Memo no.: IND/WB/FES/20192020/52582

Date: 21-09-2023

From:  
Divisional Fire Officer, North 24 Parganas  
West Bengal Fire & Emergency Services

To: EAST POINT SCHOOL  
ICHHAPUR, P.O.-NAWABGANJ, P.S.-NOAPARA, DIST.-NORTH 24 PGS

Sub: Renewal of Fire Safety Certificate for the occupancy of an existing construction of G+II storied school building under group of Educational building in the name & style "M/S East Point School" at the premises No. Ichapur, Anandamath of R.S. Dag No. 3016, 3031, 3032, 3031/3307, 3035 & 3031/3308 in R.S. Khatian no. 1013, 2413, 232, 3599, 2330 & respectively of Mouza- Ichapur, J.L. No.-3, Touzi No. 617, R.S.No.-89, Holding No.-505/23 ward no. 06 under North Barrackpore Municipality, P.S.- Noapara, Dist.-24Pgs. North, West Bengal.

This is in reference to your application no. 0125191231100815 dated 06-09-2023 regarding the Renewal of Fire Safety Certificate for the occupancy of an existing construction of G+II storied school building under group of Educational building in the name & style "M/S East Point School" at the premises No. Ichapur, Anandamath of R.S. Dag No. 3016, 3031, 3032, 3031/3307, 3035 & 3031/3308 in R.S. Khatian no. 1013, 2413, 232, 3599, 2330 & respectively of Mouza- Ichapur, J.L. No.-3, Touzi No. 617, R.S.No.-89, Holding No.-505/23 ward no. 06 under North Barrackpore Municipality, P.S.- Noapara, Dist.-24Pgs. North, West Bengal.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

**Recommendation:**

Driveway must have to be kept free of obstruction at all time for EASY movement of fire Appliances. No parking will be allowed on the driveway.

2. The interior finish decoration of building shall be made with low flame spread material confirming I.S. specification.
3. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the Building shall be strictly maintained.

4. Existing Electrical wiring of the whole building shall have to be carefully checked for any damage in wear and tear in them, particularly lines above false ceiling & ducts.
5. A fire control room including a close circuit T.V. / Monitor system will have to be installed which will observe all the floor of the Building.
6. The notice of Fire Fighting equipments and Evacuation plan shall be maintained and displayed at all venerable places of the Building.
7. The Employees and security staff shall be well conversant with installed Fire Fighting Equipments of the building and to operate in the event of Fire and Testing.
8. Mock Fire practice evacuation drill shall to be performed periodically with participant of all the occupants of the building.
9. Main and meter room shall be protected with Co2 or DCP Fire Extinguishers confirming I.S. Specifications.
10. First-Aid Fire Fighting system shall be provided as per I.S. Specification.
11. Arrangement shall have to be made for regular checking, testing and maintenance, of all the Fire Fighting installation of the Building to keep them in perfectly good working Condition at all the time.
12. If required the old line shall have to be replaced with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
13. Periodical flashing of water in hydrants pipe line shall be made to maintain the efficient working performance of above mentioned system.
14. Fire Safety audit to be conducted at regular interval and to be recorded in the fire prevention maintenance register.
15. Fire Licence shall have to be obtained from the licence section of the department for proposed storing of highly combustible articles and procession with L.P.G., which come under purview of licence section as per Fire service Act-1950 (with up to date amendment).
17. This Fire Safety Certificate is valid for **Three years** and have to be renewed every three years interval from the date of Issue of this letter. In every three years Certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services, regarding the Performance of all the life & Fire Safety arrangements and installation of the Building.
18. Any deviation or changes the building in respect of the approved plan drawing, without prior permission from this office, this fire safety certificate will be treated cancelled automatically.

Signature Not Verified  
Digitally signed by SAROJ  
KUMAR BAG  
Date: 2023.09.21 21:26:07 IST

Divisional Fire Officer, North 24 Parganas  
West Bengal Fire & Emergency Services